



AMCO SPECTRO

AND MATERIAL TESTING LAB LLP

Tel. : +91-9266-69-9990
+91-9891-57-3910

Lab : A-71, Group Wazirpur Industrial Area, New Delhi-110052
Web : www.testinglabindia.com, Email : amcotestinglab@gmail.com



TEST REPORT

FF : 7.8.1.1

| | | | |
|--|---|---------------------------|------------------------------|
| Issued To: | M/s. Infant Jesus School Dwarka Qutub Vihar, Phase-1, Near Sector-19B, Dwarka, New Delhi-110071 | Work Order No | AMCO/480/16 |
| | | Report No | 26040616 |
| Page 1 of 1 | Delhi, India. | Date of Receipt | 06-04-2026 |
| | | Party Ref. No: | PV & Verbal Dated 06-04-2026 |
| | | Order Confirmation Date | 06-04-2026 |
| | | Analysis Start Date | 06-04-2026 |
| Sample Quantity: | Approx 1 litre | Analysis End Date: | 11-04-2026 |
| Lot No/Batch No | NS | Date of Issue: | 11-04-2026 |
| Date of Manufacturing | NS | Sample Deposited by Party | |
| Sample Description: One Sample described by party as Drinking water was received for the following tests only. | | | |

TESTS RESULTS

WATER SAMPLE ANALYSIS REPORT

| S.NO | TESTS | TEST METHODS | RESULTS | REQUIREMENTS | CONFORMITY |
|------------------------------|--|----------------------------------|-------------|--|------------|
| | | | | As per (IS:10500-2012) Ammn 2 | |
| 1 | Odour | IS: 3025 (PART-5)-2018 RA: 2022 | Agreeable | Agreeable | YES |
| 2 | Taste | IS: 3025 (PART-7) :2017 RA 2022 | Agreeable | Agreeable | YES |
| 3 | Colour, Hazen Units | IS: 3025 (PART-4)-2021 | <5 | A. 5 max as acceptable limit B. 15 max as Permissible Limit | YES |
| 4 | pH Value @25° C | IS: 3025 (PART-11)-2022 | 7.52 | 6.5 to 8.5 | YES |
| 5 | Total Dissolved Solids, mg/l | IS: 3025 (PART-16)-2023 | 71 | A. 500 max as acceptable limit B. 2000 max as permissible limit | YES |
| 6 | Turbidity, NTU | IS: 3025 (PART-10)-2023 | <1 | A. 1 max as acceptable limit B. 5 max as permissible limit | YES |
| 7 | Chloride as Cl ⁻ , mg/l | IS: 3025(PART-32)-1988 RA: 2019 | 21.3 | A. 250 max as acceptable limit B. 1000 max as permissible limit | YES |
| 8 | Calcium as Ca, mg/l | IS: 3025 (PART-21)-09RA: 2023 | 3.92 | A. 75 max as acceptable limit B. 200 max as permissible limit | YES |
| 9 | Magnesium as Mg, mg/l | IS: 3025 (PART-46)-2023 | 4.70 | A. 30 max as acceptable limit B. 100 max as permissible limit | YES |
| 10 | Total Hardness as CaCO ₃ , mg/l | IS: 3025 (PART-21)-2009 RA: 2023 | 29.4 | A. 200 max as acceptable limit B. 600 max as permissible limit | YES |
| 11 | Flouride as F, mg/l | IS:3025 (PART 60)-2008 RA 2023 | BDL(DL=0.1) | A. 1.0 max as acceptable limit B. 1.5 max as permissible limit | YES |
| 12 | Iron as Fe, mg/l | IS: 3025 (PART-53)-2003 RA: 2023 | BDL(DL=0.1) | A. 1.0 max as acceptable limit | YES |
| BACTERIOLOGICAL TESTS | | | | | |
| 13 | Coliform | IS: 15185-2016 | Absent | Shall not be detectable in any 100ml sample | YES |
| 14 | E. Coli | IS: 15185-2016 | Absent | Shall not be detectable in any 100ml sample | YES |

Note:1) BDL: Below Detection Limit. 2) Figure in bracket indicates Limit of Quantification, 3) ND= Not detected, DL= Detection Limit.
Remarks: The above sample confirms to IS: 10500-2012 wrt above tests only.



Authorised Signatory

REVIEWED BY

[Signature]

Civil / Mechanical / Chemical / NDT TESTING

1. The results listed refer only to samples and applicable parameters. 2. Endorsement of product is neither inferred nor implied. 3. Total liability of our lab is limited to the invoiced amount. 4. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 5. Perishable samples will be destroyed in 2 to 7 days as applicable. 6. The Report shall not be reproduced except in full without written approval of Laboratory. 7. Report refers to the sample submitted to us and not drawn by Amco Spectro and Material Testing Lab LLP unless mentioned otherwise. 8. Retesting Charges will be applicable if results are reproducible. 9. Duplicate copy will be issued on chargeable basis. 10. In case of any dispute, the jurisdiction shall be New Delhi Courts.